

8.0	Ammonia NH₃								
8.1	Zero point (fresh air) - Display -3 – +3 ppm								
8.2	Test gas 50 ppm - Display 45 – 55 ppm								
8.3	Visual alarm (e.g.: Y / N)								
8.4	Audible alarm (e.g.: Y / N)								
9.0	Comments - Maintenance required (inspection plate) - Lifetime sensor exceeded - Adjustment, repair - or similar								
10.0	Inspection								
	- Day								
	- Month								
	- Year								
	- Signature								